



Sweetwater Environmental Management, LLC

720 East Landis Avenue, Rear
Vineland, New Jersey 08360

School Potable Water System Lead Testing

**Caroline L. Reutter School
2150 Delsea Drive
Franklinville, NJ 08322**

07/31/2017

Prepared By:
Frederick J. Gross, REM • CEA • LO
Sweetwater Environmental Management, LLC

Drinking Water Outlet Inventory & Results

Name of School: Caroline L. Reutter School Address: 2150 Delsea Drive, Franklinville, NJ 08322

Date Completed: 7-12-2017

#	Outlet Type	Location	Code	Lead Result ug/l *	Lead Limit ug/l *	Map ID	Comments
1	Water Cooler	East West Hall	CRS-EWHL-WC-01	<1	15	01	SAMPLE, In compliance
2	Sink	Room 33	CRS-RM33-TL-02	2.66	15	02	SAMPLE, In compliance
3	Sink	Staff Restroom	CRS-STBR-BS-02.1	N/A	N/A	02.1	Non-Drinking Water Outlet, No Sample
4	Sink	Staff Restroom	CRS-STBR-BS-02.2	N/A	N/A	02.2	Non-Drinking Water Outlet, No Sample
5	Sink	Room 19	CRS-RM19-AS-03	3.33	15	03	SAMPLE, In compliance
6	Sink	Room 19	CRS-RM19-AS-04	2.51	15	04	SAMPLE, In compliance
7	Sink	Room 19	CRS-RM19-AS-05	3.42	15	05	SAMPLE, In compliance
8	Sink	South West Girl's Room	CRS-SWHG-BS-06	N/A	N/A	06	Non-Drinking Water Outlet, No Sample
9	Sink	South West Girl's Room	CRS-SWHG-BS-07	N/A	N/A	07	Non-Drinking Water Outlet, No Sample
10	Sink	South West Girl's Room	CRS-SWHG-BS-08	N/A	N/A	08	Non-Drinking Water Outlet, No Sample
11	Bubbler	South West Hall	CRS-SWHL-DW-09	3.06	15	09	SAMPLE, In compliance
12	Sink	South West Boy's Room	CRS-SWHB-BS-10	N/A	N/A	10	Non-Drinking Water Outlet, No Sample
13	Sink	South West Boy's Room	CRS-SWHB-BS-11	N/A	N/A	11	Non-Drinking Water Outlet, No Sample
14	Sink	South West Boy's Room	CRS-SWHB-BS-12	N/A	N/A	12	Non-Drinking Water Outlet, No Sample
15	Bubbler	South West Hall	CRS-SWHL-DW-13	2.79	15	13	SAMPLE, In compliance
16	Sink	Room 32	CRS-RM32-BS-14	N/A	N/A	14	Non-Drinking Water Outlet, No Sample

* ug/l = Micrograms per Liter or Parts per Billion

TABLE KEY

	Sample collected, the result was less than the LEAD Action Limit (15 ug/l), sample is acceptable for potable water.
	Sample collected, the result was greater than the LEAD Action Limit (15 ug/l), outlet was removed and plumbing sealed.
N/A	NO Sample collected, outlet exempted, NOT A DRINKING WATER SOURCE, sanitation only hand wash or equipment sink

#	Outlet Type	Location	Code	Lead Result ug/l *	Lead Limit ug/l *	Map ID	Comments
17	Sink	Room 30	CRS-RM30-BS-15	N/A	N/A	15	Non-Drinking Water Outlet, No Sample
18	Bubbler	North Hall	CRS-NHL-DW-16	12.6	15	16	SAMPLE, In compliance
19	Sink	Room 38	CRS-RM38-NS-17	2.25	15	17	SAMPLE, In compliance
20	Sink	Kitchen Prep Sink	CRS-KIT1-KC-18	2.48	15	18	SAMPLE, In compliance
21	Sink	Kitchen Dish Sink	CRS-KIT1-DS-19	51.7	15	19	Outlet, Permanently Removed
22	Sink	Kitchen Dish Sink	CRS-KIT1-DS-19.1	17.9	15	9.1	Outlet, Permanently Removed
23	Sink	Kitchen Prep Sink	CRS-KIT2-KC-20	3.35	15	20	SAMPLE, In compliance
24	Sink	Kitchen Dish Sink	CRS-KIT2-DS-21	4.95	15	21	SAMPLE, In compliance
25	Sink	Kitchen Hand Sink	CRS-KIT3-HS-22	9.62	15	22	SAMPLE, In compliance
26	Bubbler	East West Hall	CRS-EWHL-DW-23	N/A	N/A	23	Permanently, Out Of Service
27	Bubbler	East West Hall	CRS-EWHL-DW-24	N/A	N/A	24	Permanently, Out Of Service
28	Sink	South East Boy's Room	CRS-SEHB-BS-25	N/A	N/A	24	Non-Drinking Water Outlet, No Sample
29	Sink	South East Boy's Room	CRS-SEHB-BS-25.1	N/A	N/A	25.1	Non-Drinking Water Outlet, No Sample
30	Sink	South East Boy's Room	CRS-SEHB-BS-26	N/A	N/A	26	Non-Drinking Water Outlet, No Sample
31	Sink	South East Boy's Room	CRS-SEHB-BS-26.1	N/A	N/A	26.1	Non-Drinking Water Outlet, No Sample
32	Water Cooler	South East Hall	CRS-SEHL-WC-27	1.43	15	27	SAMPLE, In compliance
33	Water Cooler	South East Hall	CRS-SEHL-WC-28	<1	15	28	SAMPLE, In compliance
34	Sink	South East Girl's Room	CRS-SEHG-BS-29	N/A	N/A	29	Non-Drinking Water Outlet, No Sample
35	Sink	South East Girl's Room	CRS-SEHG-BS-30	N/A	N/A	30	Non-Drinking Water Outlet, No Sample
36	Bubbler	South East Hall	CRS-SEHL-DW-31	N/A	N/A	31	Permanently, Out Of Service
37	Sink	Room 41 Library Office	CRS-RM41-KC-32	18.6	15	32	Outlet, Permanently Removed

* ug/l = Micrograms per Liter or Parts per Billion

TABLE KEY





	Sample collected, the result was less than the LEAD Action Limit (15 ug/l), sample is acceptable for potable water.
	Sample collected, the result was greater than the LEAD Action Limit (15 ug/l), outlet was removed and plumbing sealed.
N/A	NO Sample collected, outlet exempted, NOT A DRINKING WATER SOURCE, sanitation only hand wash or equipment sink

#	Outlet Type	Location	Code	Lead Result ug/l *	Lead Limit ug/l *	Map ID	Comments
38	Sink	Room 41	CRS-RM41-HS-33	12.2	15	33	SAMPLE, In compliance
39	Water Cooler	North Hall	CRS-NHL-WC-34	<1	15	34	SAMPLE, In compliance
40	Bubbler	North Hall	CRS-NHL-DW-35	12.8	15	35	SAMPLE, In compliance
41	Sink	North East Boy's Room	CRS-NEHB-BS-36	N/A	N/A	36	Non-Drinking Water Outlet, No Sample
42	Sink	North East Boy's Room	CRS-NEHB-BS-36.1	N/A	N/A	36.1	Non-Drinking Water Outlet, No Sample
43	Sink	North East Boy's Room	CRS-NEHB-BS-37	N/A	N/A	37	Non-Drinking Water Outlet, No Sample
44	Bubbler	North East Hall	CRS-NEHL-DW-38	1.74	15	38	SAMPLE, In compliance
45	Sink	North East Girl's Room	CRS-NEHG-BS-39	N/A	N/A	39	Non-Drinking Water Outlet, No Sample
46	Sink	North East Girl's Room	CRS-NEHG-BS-39.1	N/A	N/A	39.1	Non-Drinking Water Outlet, No Sample
47	Sink	North East Girl's Room	CRS-NEHG-BS-40	N/A	N/A	40	Non-Drinking Water Outlet, No Sample

* ug/l = Micrograms per Liter or Parts per Billion

TABLE KEY

	Sample collected, the result was less than the LEAD Action Limit (15 ug/l), sample is acceptable for potable water.
	Sample collected, the result was greater than the LEAD Action Limit (15 ug/l), outlet was removed and plumbing sealed.
N/A	NO Sample collected, outlet exempted, NOT A DRINKING WATER SOURCE, sanitation only hand wash or equipment sink

-  1952 CONSTRUCTION
-  1958 ADDITION
-  2007 ADDITION
-  2012 REMODELED



SWEETWATER
ENVIRONMENTAL
MANAGEMENT, LLC

720 East Landis Avenue, Rear
Vineland, NJ 08360
Phone: (856) 205-1999
Fax: (856) 205-1825

DRAWN BY
FJG

FILE
FBE

DATE
06/30/2017

SCALE
NTS

Potable Water Inventory / Lead Sampling Map
Caroline L. Reutter School
2150 Delsea Drive
Franklinville, NJ 08322

PREPARED FOR:
Franklin Township Board of Education